City of Fort Atkinson
City Electrician's Office
101 N. Main Street
Fort Atkinson, WI 53538

MEMORANDUM

FROM: **Jeff Armstrong, City Electrician**
jarmstrong@fortatkinsonwi.net
(920) 563-7765

RE: **Temporary Power Requirements for Special Events**

All temporary power that is being sourced from City of Fort Atkinson power pedestals must meet the following requirements.

1) All extension cords operating at 120-volts shall be of 12-gauge wire minimum, with a ground wire. All cords shall be free of cuts, splices and any exposed wires.

2) Extension cord connections shall be limited to 1900 Watts/16 Amps at 120 volts. If you have any questions on your equipment please feel free to call or check the manufacture's tag.

3) No open wire pigtails or adaptors allowed.

4) All cord connection shall be secure and free of exposure to harsh conditions and weather.

5) Length shall be limited to 25 feet, if longer is required an approved connection covering will be required at the point of a cord to cord connection.

6) Ground Fault protection (GFCI) will be the responsibility of the end user.

7) All 240-volt connections shall be approved prior to the event thru the Fort Atkinson Electrical Department, requirements will be discussed at that time.